

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No. 751

Date: 10/6/2025

It is certified that an inspection team headed by Amit Behena  
Superintendent CHC (Name of Officers with designation) from  
CHC Marshaghai, Kendrapara (Name of Department / Office)  
inspected the **ZENITH INTERNATIONAL SCHOOL, SAMGUDIA , ANGULEI-ICHHAPUR  
ROAD, KENDRAPARA, ODISHA-754212** (Name and Address of the School) on  
10/6/25 and found that the **ZENITH INTERNATIONAL SCHOOL,  
SAMGUDIA , ANGULEI-ICHHAPUR ROAD, KENDRAPARA, ODISHA-754212**(Name of  
the School) has safe drinking water facilities for the students and members of staffs of  
the institution and is maintaining the hygienic sanitation condition in the school  
building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period for 02(TWO) YEARS.

Signature with Seal: 

Name: Amit Behena

Designation: Medical officer, Marshaghai

Public Health Department (PHED) / Authorized officer of  
the Local Body Name & Address of the Office / Department:

To  
Principal  
Zenith International School  
Kendrapara.

(Name & Address of the Institution)



**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER  
R.W.S & S SUB-DIVISION, KENDRAPARA.**

Letter No.....751...../Date..10.06.2025.....

To,

The Principal  
Zenith International School  
Near Sri Baladevjiew Temple  
Angulai-Ichhapur Road, Kendrapara

Sub :- Test report of water sample


Ref:- Your letter No. **ZIS/56/2025** dated **03/06/2025**


Sir,

With reference to your letter as cited above I am furnishing herewith the test report of water sample received from the laboratory for analysis which is enclosed herewith for your information.

Encl: Test Report

Yours Faithfully

  
Asst. Executive Engineer  
R.W.S & S Sub- Division,  
Kendrapara

  
10/06/25



**DISTRICT WATER TESTING LABORATORY, RWS&S DIVISION, KENDRAPARA.**

email : eerwss ctc2@nic.in

**Analytical Report**

Name of the Customer :- **Principal  
Zenith International School, Angulai, Kendrapara**

Sample Registration Details	
Type of Source :	Bore well
Date of Sample Collection :	09/06/2025
Sample Receive Date :	09/06/2025
Sample Registration Date :	09/06/2025
Quantity of Sample Received :	1000 ml.
Sample Collected by :	Not specified
Location of the Sample :	Near Sri Baladevjiew Temple, Angulai-Ichhapur Road, Kendrapara
Sampling Protocol :	Sample not collected by this Laboratory.
Period of Analysis :	From dt. 09/06/2025 to 10/06/2025
Testing Protocol :	As per Bureau of Indian Standard (BIS)


Sl. No	Test Parameters	Units	Tested Result	Requirements IS 10500 : 2012		Test Method
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	Total Hardness (as CaCO <sub>3</sub> )	mg/l	150	200	600	EDTA Titrimetric Method (APHA 23 <sup>rd</sup> ED 2340 C)
2	Turbidity	NTU	1.80	1	5	Nephelometric Method (APHA 23 <sup>rd</sup> Ed-2130.B)
3	Fluoride	Mg/l	0.0472	1.0	1.5	Ion Selective Method
4	Iron	Mg/l	0.139	1.0	No relaxation	Phenonthroline Method (APHA 23 <sup>rd</sup> ED 3500 - Fe B)
5	pH		6.65	6.5 to 8.5	No relaxation.	Electrometric Method, APHA 23 <sup>rd</sup> ED 4500-H+ B)
6	Alkalinity (as CaCO <sub>3</sub> )	mg/l	170	200	600	Titration Method (APHA 23 <sup>rd</sup> ED 2320 B)
7	Chloride	Mg/l	140	250	1000	Argentometric Method (APHA 23 <sup>rd</sup> ED 4500 - Cl- B)
8	Elect. Conductivity	uScm	465	-	-	Instrumental method (APHA 23 <sup>rd</sup> ED 2510 B)
9	TDS	Mg/l	302.25	500	2000	Calculation method
10	Total Coli form	CFU / 100ml	Nil	Shall not be detected in any CFU/100 ml sample	No relaxation.	Membrane Filter method


Remarks :-Water is portable.

**Information on Test Report :**

- Results relates only to the item tested
  - The test report shall not be reproduced except in full without written approval of DWTLK.
- \* APHA – American Public Health Association.**

N.B :- This certificate will valid one year from the date of issue

  
Lab. Chemist  
RWS&S District Laboratory,  
Kendrapara

  
Jr. Lab Assistant  
RWS&S District Laboratory,  
Kendrapara